



DETAIL AT HEAD OF POST

DETAILS OF HYDRANT MARKER PLATES POST

NOTES

1. THE PLATES SHALL BE THOROUGHLY CLEANED WITH A ZINC BASED PRIMER & PAINTED TWO COATS BLACK ENAMEL GLOSS FOR THE FIGURES, TWO COATS YELLOW REFLECTIVE PAINT FOR THE BACKGROUND. THE POST SHALL BE SIMILARLY PAINTED YELLOW.
2. MARKER POSTS SHALL NOT BE CONCRETED TO THE GROUND UNLESS IF ROCK IS PRESENT OR IF THE BASE OF THE POST IS LESS THAN 600mm BELLOW GROUND LEVEL THEN 0.03 Cu m OF CONCRETE SHALL BE



SECTION B – B



HYDRANT



SECTION



WATER METER (Reverse)



SECTION

VALVE PLATE INDICATOR PLATE

AIR VALVE MARKER

DOUBLE AIR VALVE & BOX PLAN



TYPICAL THRUST BLOCK ON BENDS



NOTES:	AMENDMENT	Description :	, Ministry of Local Government, Public Works and National Housing P.O. Box CY7755 , Causeway Zimbabwe	Arch Eng V.D	Director Eng H.Hungwe	Ministry MINISTRY OF FINANCE	Centre MUTARE
				Designed L.M	Branch Head E.N	Title FORBES BORBER POST STAFF COTTAGES	
				Drawn L.M	Scale N.T.S	Description STANDARD WATER DETAILS	
				Checked E.M	Date Mar 2022		G.P. No / Proj
				Telephone 04 700811			