

**ZIMBABWE REVENUE AUTHORITY
COMMISSIONER GENERAL**



WRITE TO:
THE COMMISSIONER GENERAL
ZIMBABWE REVENUE AUTHORITY
PO BOX 4360
HARARE

TELEPHONE:
+263-4-758891/5
FAX:
+263-4-707400
TELEGRAPHS:
HARARE

CALL AT:
RECEPTION
6th FLOOR ZB CENTRE
CORNER KWAME NKRUMAH
AVE/ FIRST STREET
HARARE

IN REPLY PLEASE QUOTE:
NCB26/2022

09 May 2022.

TO ALL PROSPECTIVE BIDDERS.

ADDENDUM NO.2 TO ZIMRA TENDER NCB 26 of 2022 FOR THE SUPPLY, DELIVERY, INSTALLATION AND COMMISSIONING OF BACK-UP POWER FOR M7 AND M8 SERVERS AT ZIMRA KURIMA DATA CENTRE.

Reference is made to the site meeting held on 09 May 2022 for the above captioned tender. Please take note of the following changes to the tender:

- 1) The **Inverter** has been changed from 10 KVA to 15 KVA and must be monitored remotely.
- 2) The **Protection Unit** must have the following components:
 - **A.C Side:**
 - i) Surge Protector (30 Amp)
 - ii) 1000 Volts Surge Protective Device (SPD)
 - iii) 3 x Triple Pole 16 Amp MCBs
 - **D.C Side:**
 - i) 300 Amps Isolator
 - ii) 9 x Din Type 63 Amps Change Over Switch (Changeover seamless)
 - iii) Distribution Board Housing
- 3) **Additional Materials:**
 - **Cables:**
 - i) 15 metres x Red Battery Cable
 - ii) 15 metres x Black Battery Cable
 - iii) 30 metres x AC 3 Core 4mm Cable

All other requirements remain unchanged as per the NCB 26 of 2022 Bidding Document including the closing date of 13 May 2022.

Yours faithfully

T. Shonhiwa (Mr.)

Director Procurement Management Unit

