



**ZIMBABWE REVENUE AUTHORITY
COMMISSIONER GENERAL**

WRITE TO:
**THE COMMISSIONER
GENERAL
ZIMBABWE REVENUE
AUTHORITY
PO BOX 4360
HARARE**

TELEPHONE:
+263-4-758891/5
FAX:
+263-4-707400
TELEGRAPHS:
HARARE

CALL AT:
**RECEPTION
6th FLOOR ZB CENTRE
CORNER KWAME
NKRUMAH AVE/ FIRST
STREET
HARARE**

IN REPLY PLEASE QUOTE:
NCB 22/2022

23 May ,2022

Attention: All Bidders

ADDENDUM NO.1 TO ZIMRA TENDER NO NCB 22/2022 FOR THE SITING AND DRILLING OF A BOREHOLE AND INSTALLATION OF A SOLAR PUMPING SYSTEM AND EQUIPMENT AT SANGO BORDER POST.

Following a site meeting held on the 17th of May 2022 at Sango Border Post, Bidders are advised to take note of the below changes and notes on the above mentioned tender;

1. Bidders must adhere to the wet hole policy and the capacity test must meet a minimum of 1500 litres per hour.
2. In the event that one hole would not be adequate in terms of capacity, Bidders will make use of two holes.
3. Due to high temperatures being experienced at Sango Border Post, Bidders must make sure that the tanks are of heat resistant material.
4. In terms of the Pumping System, Bidders must provide a provisional sum.
5. Bidders must submit a Siting Report before drilling.
6. Bidders must include the cost of getting a drilling permit from Zimbabwe National Water Authority (ZINWA).
7. Bidders must provide Water Quality Test and purification provisional sum.

All other requirements remain unchanged as per the NCB 22 of 2022 Bidding Document.

Yours Faithfully;

**B.E Mushanyuri (Dr.)
Acting Director, Procurement Management Unit.**

