

**ZIMBABWE REVENUE AUTHORITY  
COMMISSIONER GENERAL**



WRITE TO:  
[CGOffice@zimra.co.zw](mailto:CGOffice@zimra.co.zw)  
or  
ZIMBABWE REVENUE  
AUTHORITY  
PO BOX 4360  
HARARE

TELEPHONE:  
+263-242-775332  
752 046  
FAX:  
+263-242-774087

CALL AT:  
RECEPTION  
6<sup>th</sup> FLOOR, ZB CENTRE  
59 KWAME NKRUMAH AVE  
HARARE

IN REPLY PLEASE QUOTE:  
REF: ZIMRA NCB 26/2022

23 May 2022

**TO ALL PARTICIPATING BIDDERS**

**ADDENDUM 1 TO TENDER ZIMRA NCB 22/2022 FOR THE SUPPLY, DELIVERY,  
INSTALLATION AND COMMISSIONING SOLAR SYSTEMS AT MPLAMBAPELE  
AND TWO BULAWAYO HOUSES**

Following our site meeting held on the 18<sup>th</sup> and 19<sup>th</sup> of May 2022 in Bulawayo and at Mulambapele Border Post, respectively, for the above captioned works, the below was agreed on by all the participants;

**LOT 1 – BULAWAYO STAFF HOUSES**

- i) Bidders to install and connect on ZESA, a separate 15A double wall socket for the washing machine, on the first house
- ii) Hours of power were agreed to be between 18 to 24hours for both houses
- iii) Inverter size to change to a 5KV, 48V.
- iv) Lithium batteries to change to 48kwh, pylontech or equivalent brand. Minimum 5c. (technical data sheet must also be submitted)
- v) Solar panels to increase to 12. 6 for each house.
- vi) Maximum load expected to be 1200kw
- vii) Galvanised or aluminium mounting racks to be used.

**LOT 2 – MLAMBAPELE BORDER POST**

- i) Bidders to supply, deliver, install and commission 12 by 200W fully integrated street solar lights with lithium batteries, to provide lighting for 12hours.
- ii) 8 street lights poles should have a base of 110mm in diameter, and 7 metres in length. 4 poles for butterfly lights (8 lights) and the other 4 poles for 4 single lights.
- iii) Butterfly wings should be 600mm from the pole.
- iv) Mounting of solar panel stand, using painted mild steel, of galvanised angle iron measuring 40mm x 40mm, with a minimum height of 1m and max height of 2.5m, and 7m long.
- v) Solar panels to increase from 4 panels to 6 panels.



In addition to the technical changes, please also take note of the below;

- i) The warranty period for the panels must be a minimum of 5 years
- ii) Evaluation and award shall be done on a lot by lot basis.
- iii) There is no limit the number of lots the bidders can quote for.
- iv) There is no limit to the number of lots to be awarded to a bidder.

*All the other requirements in bidding document remains unchanged.*

Thank you



**B. MUSHANYURI**  
**ACTING DIRECTOR, PROCUREMENT MANAGEMENT UNIT**

