



**ZIMBABWE REVENUE AUTHORITY
COMMISSIONER GENERAL**

WRITE TO:
CGOffice@zimra.co.zw
ZIMBABWE
REVENUE
AUTHORITY
PO BOX 4360
CAUSEWAY
HARARE

TELEPHONE:
+263-4-736111
FAX:
+263-4-707400
TELEGRAPHS:
HARARE

CALL AT:
RECEPTION
1st FLOOR KURIMA
HOUSE
NELSON
MANDELA AVE
HARARE

IN REPLY PLEASE
QUOTE:

REF: NO.
ZIMRA NCB
57/2022

12 October 2022

To All Participating Bidders

**ADDENDUM NO. 1 TO ZIMRA DOMESTIC TENDER NO. NCB 57/2022 FOR THE
PARTITIONING OF OFFICES, CONSTRUCTION OF ABLUTION FACILITIES AND
STRONG ROOM AT ZIMRA CENTRAL STORES.**

Following the compulsory site meeting held on the 4th of October 2022 at The Zimbabwe Revenue Authority (ZIMRA) Central Stores, bidders must take note of the following changes and additions;

Questions

1. What is the type and finish of the doors?
2. What is the type and thickness of the glass?
3. What are the specifications of the ceiling tiles?
4. Will strong room have concrete ceiling?
5. What is the description of works for Ablutions sewer and drainage?

Answers

1. Internal quality hollow core flush door with hardwood edges all round with veneers both sides suitable for painting with overall size 44 x 813 x 2030mm.
Color of paint to be chosen and advised.
2. 3cm thickness tempered clear glass.
3. 600 x 600mm fine textured USG or equivalent approved ceiling tiles.

4. Strong room will not have concrete ceiling, but will have ceiling tiles.
5. Drainage to connect to existing council line. Exposed sewer pipes to be encased in brickwork. Repatching of bitumen tar where excavations will be carried out on existing pavement for sewer. Manhole to be put at connection point and abc after 25m run.

NB: All the other requirements in the bidding document including the closing date will remain unchanged as per bidding document.

Thank you



J. Tarume
Acting Director, Procurement Management

