

**ZIMBABWE REVENUE AUTHORITY  
COMMISSIONER GENERAL**

WRITE TO:  
CGOffice@zimra.co.zw  
ZIMBABWE  
REVENUE  
AUTHORITY  
PO BOX 4360  
CAUSEWAY  
HARARE

TELEPHONE:  
+263-4-736111  
FAX:  
+263-4-707400  
TELEGRAPHS:  
HARARE

CALL AT:  
RECEPTION  
1<sup>st</sup> FLOOR KURIMA  
HOUSE  
NELSON  
MANDELA AVE  
HARARE

IN REPLY PLEASE  
QUOTE:

REF: NO.  
ZIMRA NCB  
14/2023

13 April 2023

To All Participating Bidders

**ADDENDUM NO. 1 TO ZIMRA DOMESTIC TENDER NO. NCB14/2023 FOR THE SUPPLY, DELIVERY AND COMMISSIONING OF AIR CONDITIONERS AT ZIMRA HWANGE OFFICE, VICTORIA FALLS TOWN OFFICE, VICTORIA FALLS BORDER, KAZUNGULA BORDER POST AND PANDAMATENGA BORDER POST.**

Following compulsory site meetings held on 3,4,5 and 6 April 2023 at The Zimbabwe Revenue Authority (ZIMRA) offices in Hwange, Victoria Falls Town, Victoria Falls Border Post, Pandamatenga Border Post and Kazungula Border Post respectively, bidders must take note of the following changes and Notes for each station;

**1. ZIMRA HWANGWE OFFICES**

- a. Bidders must change the size of 1 x Air Conditioner from 24000 BTU Mid Wall R410a to 12000 BTU Mid Wall R410a.
- b. Bidders must include and indicate the cost of 30 metres 4 core, 8mm armored cable.
- c. Bidders must include and indicate the cost of 3 x three phase breakers 60 Amps and 7 x single phase breakers 20 Amps.
- d. Bidders must include and indicate the cost of 1x1500mm Air Curtain.
- e. Bidders must include and indicate the cost of 1x 8 Way Distribution Board, 1x 6 way Distribution Board and 1x Sub Distribution Board.

## **2. VICTORIA FALLS TOWN OFFICES**

- a. Bidders must include and indicate the cost of 1x1200mm Air Curtain.
- b. Bidders must include the cost of 1x Air Conditioner 24000 BTU Mid Wall R410a
- c. Bidders must include the cost of 1x Air Conditioner 12000 BTU Mid Wall R410a
- d. Bidders must include and indicate the cost of 1 x three phase breakers 60 Amps and 9 x single phase breakers 20 Amps.

## **3. VICTORIA FALLS BORDER**


- a. Bidders must include and indicate the cost of 30 metres 3 core, 2.5mm flex cable.
- b. Bidders must change the size of 1x Air Curtain from 1200mm to 1800mm

## **4. KAZUNGULA BORDER POST**

- a. Bidders must include and indicate the cost of 1x Air Conditioner 24000 BTU Mid Wall R410a
- b. Bidders must change the size of 1x Air Curtain from 1200mm to 1500mm
- c. Bidders must include the cost of 4x Air Conditioner 12000 BTU Mid Wall R410a
- d. Bidders must include and indicate the cost of additional 4x1500mm Air Curtain
- e. Bidders must include and indicate the cost of 2 x three phase breakers 60 Amps, 11 x single phase breakers 20 Amps and 2 x three phase breakers 40 Amps
- f. Bidders must include and indicate the cost of 20 metres 4 core, 8mm armored cable.
- g. Bidders must include and indicate the cost of 1x 9 way Distribution Board

## **5. PANDAMATENGA BORDER POST**

- a. Bidders must include and indicate the cost of 1x Air Conditioner 18000 BTU Mid Wall R410a
- b. Bidders must change the size of 2x Air Curtain from 1200mm to 1500mm
- c. Bidders must include and indicate the cost of 1 x three phase breakers 60 Amps, 6 x single phase breakers 20 Amps and 2 x three phase breakers 40 Amps
- d. Bidders must include and indicate the cost of 20 metres 4 core, 4mm armored cable and 150 metres 3 core, 2.5mm flex cable
- f. Bidders must include and indicate the cost of 1x 2 Way Distribution Board, 1x 12 way Distribution Board and 6x Geyser switch 20 Amp double pole



13

### **NOTES TO ALL BIDDERS**

1. All air conditioning pipes must be made of Copper material.
2. Each Air Conditioner must have its own isolation distribution board
3. Distribution boards must be all weather
4. All outside pipes exposed to be run in trunking.
5. All air conditioner drainage must be run from unit to the ground at the building using conduit pipes.
6. All units to have remote control and user manual for operation.
7. All main power cables must run on cable tray

**NB: All the other requirements in the bidding document including the closing date remain unchanged.**

Thank you



**T. Shonhiwa**  
**Director, Procurement Management**

